

NORTHFIELD FACILITIES LAB

FACILITY MAINTENANCE RECORD

ANONYMIZED TEST RECORD · NO PERSONAL DATA

Work order: **RC-1087**

Visit date: **14 Aug 2026**

Meter reading: **8,016.4 kWh**

Equipment: **AHU-04**

Required action: **Replace filter before 30 Sep 2026**

TECHNICIAN NOTE

Fan noise not present after restart.